



Incident Information

Office of Public Affairs & Education

Date:	11-07-11	Adults Injured:	0				
Time Call Received:	1159 hours	Minors Injured:	0				
Incident Type:	Structure Fire	Civilian Fatalities:	0				
Address/Location:	500 Linden St.	Civilians Rescued:	0				
Incident No:	11-14838	Firefighter Injuries:	0				
Occupancy Name:	New Belgium Brewing	Firefighter Fatalities:	0				
Occupancy / # Units	Commercial Business	Pet / Animal Fatalities/ Injuries:	0				
1 st In Company:	Engine 1	Assisting Agencies:	Fort Collins Light & Power, Police Services, Poudre Valley Hospital Ambulance				
Battalion:	1	Incident Control Time:	N/AV				
Dollar Loss:	N/AV	Incident Duration:	N/AV				
Dollars Saved:	N/AV	Total # Alarms:	2				
Displaced/Evacuated:	None	Total # Personnel	31				
Origin:	Exterior of silo	Incident Commander:	D. Lee				
Cause:	Accidental	Submitted by:	Patrick Love 1430 hours				
Engines	Ladder Trucks	Brush Engines	Rescues	Ambulances	Water Tenders	Command Units	Investigators
5	2	0	0	2	0	5	1

Fort Collins, CO- Firefighters responded to a reported empty tank on fire next to a malt silo at New Belgium Brewing just north of Old Town Fort Collins today. The first engine on scene found a fire burning insulation between the walls of a 50' tall decommissioned grain silo. Crews took immediate action to prevent the fire from spreading to another nearby silo and a malt storage facility by pouring water on the exterior of the silo that was on fire. The fire was brought under control within 30 minutes with no reported damage to the other structures.

The incident did not affect the main building and there were no evacuations and no reported injuries.

A PFA investigator determined the origin to be the exterior of the decommissioned silo. The cause was determined to be accidental; construction workers performing cutting operations.

###