



Fire Prevention Bureau

102 Remington Street
Fort Collins, CO 80524

Phone: 970-221-6570

Fax: 970-221-6635

Internet: www.poudre-fire.org

Final Test Check Sheet Fire Alarm System

Alarm, Supervisory, and Trouble

Pulls	Smoke Detectors
Heat Detectors	Duct Detectors
Water Flow	Fusible Links
Open Circuit	Loss of Power
Loss of Phone Line	Tampers

System Response

Horn and Strobes	Outside Horn and Strobe
Magnetic Door Closers	Panel Alerts

Voice	Alerts	Emergency	Lighting
Dispatch	Response	Smoke	Removal

Panel Requirements

Conduit – Any Wiring at 7 Feet or above

Batteries Dated

Information RE: Electrical Panel

Service Phone Number

Map

Dedicated Red Circuit Breaker, Locked Out, and Identified as “Fire Alarm”

Knox Box

Certificate of Completion

If you have any questions, contact Garnet England at 970-219-8651 or by email at genland@poudre-fire.org